



PER- AND POLYFLUOROALKYL SUBSTANCES (PFAS₆) REPORT SUMMARY

all samples taken at WRWS WTP finished water tap unless noted otherwise

results reflect a four (4) year running average

Sample Date	Quarter	PFAS ₆ Parameter Result (ng/L) (Acid)						
		PFOS	PFOA	PFHxS	PFNA	PFHpA	PFDA	TOTAL
		PerFluoroOctaneSulfonic	PerFluoroOctanoic	PerFluoroHexaneSulfonic	PerFluoroNonanoic	PerFluoroHeptanoic	PerFluoroDecanoic	MASSDEP GUIDELINE = 20
10/11/22	4	ND ⁽¹⁾	ND ⁽¹⁾	2.88	ND	ND ⁽¹⁾	ND	2.88
02/09/23	1	ND ⁽¹⁾	2.07	ND ⁽¹⁾	ND	ND ⁽¹⁾	ND	2.07
04/28/23	2	ND ⁽¹⁾	2.22	ND ⁽¹⁾	ND	ND ⁽¹⁾	ND	2.22
06/29/23	2	2.44	4.22	ND ⁽¹⁾	ND	ND ⁽¹⁾	ND	6.66
07/20/23	3	ND ⁽¹⁾	4.09	ND ⁽¹⁾	ND	ND ⁽¹⁾	ND	4.09
10/18/23	4	2.86	4.38	ND ⁽¹⁾	ND	ND ⁽¹⁾	ND	7.24
01/10/24	1	2.35	4.18	ND ⁽¹⁾	ND ⁽¹⁾	ND ⁽¹⁾	ND	6.53
04/10/24	2	2.30	3.40	ND ⁽¹⁾	ND	ND ⁽¹⁾	ND	5.70
07/17/24	3	3.31	5.32	ND ⁽¹⁾	ND ⁽¹⁾	ND ⁽¹⁾	ND	8.63
10/17/24	4	3.22	4.38	ND ⁽¹⁾	ND ⁽¹⁾	ND ⁽¹⁾	ND	7.60
01/22/25	1	2.41	3.65	ND ⁽¹⁾	ND	ND ⁽¹⁾	ND	6.06
04/09/25	2	3.10	3.70	ND	ND	ND	ND	6.80
07/16/25	3	3.40	4.60	ND ⁽¹⁾	ND ⁽¹⁾	2.00	ND	10.00
10/22/25	4	3.30	3.70	ND	ND	2.20	ND	9.20
01/23/26	1	2.60	3.90	ND ⁽¹⁾	ND	ND ⁽¹⁾	ND	6.50
04/08/26	2	2.30	2.80	ND	ND	ND	ND	5.10
AVERAGE RESULTS		2.10	3.54	0.18	0.00	0.26	0.00	6.08

ALL SAMPLE RESULTS ARE POST TREATMENT AT THE WTP PRIOR TO ENTERING THE WATER SYSTEM - UNLESS NOTED OTHERWISE

⁽¹⁾ Actual results may vary - reported ND as a J Qualifier

J Qualifier is defined by MassDEP as a value between the Method Detection Limit (MDL=0.596) and the Method Quantitation Limit (MRL=2.00). If the result is a J Qualifier then this is not used in the calculation to determine the PFAS₆ value, and subsequently can be assumed ND

MassDEP Maximum Contaminant Level

Monthly Sampling Trigger

WRWS Sampling Frequency

Next Sampling Period

20 ng/l

10 ng/l

Quarterly

JULY

2026



PFAS6 RESULTS - 4 YEAR RUNNING AVERAGE

