

PGB ENGINEERING, LLC

CIVIL ENGINEERING DESIGN & CONSULTING

49 TUPELO ROAD
MARSHFIELD, MA 02050-1739

Tel.: 781-834-8987
PGBEngineeringLLC@gmail.com

August 17, 2026

Hingham Planning Board
210 Central Street
Hingham, MA 02043

Subject: **33 Gardner Street, Site Plan**

Dear Planning Board Members:

This is to advise that we have reviewed the following documents pertaining to the proposed hardscaping improvements at the subject site:

- Site Plan (2 sheets), revised August 14, 2026, prepared by Morse Engineering Co., Inc. (Morse)
- Stormwater Report & Calculations, revised August 14, 2026, prepared by Morse
- Response to comments letter, dated August 14, 2026, prepared by Morse

The documents have been prepared to address comments contained in our August 11, 2026 letter to the Board. Below are the comments from our August 11th letter in plain text, followed by the current status of each in **bold text**.

1. The overflow from the proposed crushed stone trench adjacent to the existing driveway is proposed to be a 4-inch pipe that would discharge to an erosion control pad near the wetland limit. We recommend the overflow be a horizontal grate on the inspection port(s) so that overflow would flow across the grass before reaching the wetland. We also recommend an inspection port on each end of the crushed stone trench. **Addressed – the overflows from the crushed stone trench are now proposed to be horizontal grates at grade on the inspection ports and the HydroCAD model has been revised to reflect this change.**
2. General Note 8 on Sheet 1 references the incorrect FEMA Community Map Panel. The correct FEMA map is referenced in the Stormwater Report. **Addressed – the correct FEMA Community Map Panel is now noted.**
3. The transmittal letter and application indicate that the existing dwelling is a single-family, but it is labeled as multi-family on the Site Plan. **Addressed – the Site Plan now indicates that the existing dwelling is a single-family dwelling.**

Please give us a call should you have any questions.



Very truly yours,

PGB Engineering, LLC

By:

A handwritten signature in cursive script that reads "Patrick G. Brennan".

Patrick G. Brennan, P.E.

PGB